

ISO 14644-1:1999(E)

Report for Area: S09-120-00790
Report Date: 2/2/2015

ACE ELECTRIC LAB SYSTEMS
1550 KINGSHIGHWAY
ST. LOUIS , MO 63110
USA

Test Start: 2/2/2015 9:15:00AM
Occupancy State: At-rest
Clean Zone Area: 1.00 Sq. Meters

Test End: 2/2/2015 9:22:14AM
Target Class: 5
Minimum Number of Locations: 1

Counter: MetOne A2400

Serial Number: 000100515

Location Averages	0.5 μ m	No. Samples	User
1	0.00	1	
2	0.00	1	
3	35.31	1	
4	0.00	1	
5	0.00	1	

Mean of Averages 7.06
Standard Deviation 15.79
Standard Error 7.06
95% UCL 21.90
ISO Class 5 Limit 3,520.00
Test Result **PASS**

Overall Test Result: PASSES for ISO Class 5